



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20198/A		Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab			
2. Reference No.	Your TRF Dated: 15/12/2024 (Reg. No. 78802)			
3. Material Identification with details	Boiler Stack: Date and Time of Sampling: 14/12/2024 (11:40 pm to 12:10 pm), Qty. 1 No.			
4. Sample code	78802			
5. Date of sampling	14/12/2024			
6. Date of Sample testing	15/12/2024 To 20/12/2024			
7. Sampling duration (in minutes)	30 Min.			
8. Sampling Location	Boiler Stack (Unit-1 Third Unit) 660 MW			
9. Sampling Protocol	IS:11255 (Pt-1) 1985 (RA 2014)			
10. Type of stack	MS Circular			
11. Stack attached to	Boiler Stack			
12. Stack Diameter (in meters)	7.2			
13. Stack height (in meters)	275			
14. Type and quantity of fuel used	Coal			
15. Instrument Code & Calibration Status	ISSPL/INS/C/134			
16. Control Measures if any	-			
17. Ambient Temperature (oC)	26°C			
18. Flue Gas Temperature (oC)	133°C			

RESULTS

S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
3I. Chemical Testing:-					
1. Atmospheric Pollution:-					
1	Particulate Matter (PM) at 6% O2 Corr.	IS 11255 (Part 1) 1985, RA:	29	mg/Nm3	1

Page No. 1/2

Reviewed By 





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20198/A			Date	20/12/2024
S.No.	Test Parameters	Test Method	Results	Units	Detection Limit	
		2019				
2	Sulphur dioxide (SO ₂) at 6% O ₂ Corr.	USEPA 6C: 1996/By Flue Gas Analyzer	912	mg/Nm ³	0.3	
3	Oxides of Nitrogen (NO _x) at 6% O ₂ Corr.	USEPA 7E: 1990/By Flue Gas Analyzer	192	mg/Nm ³	0.2	
4	Carbon Monoxide as (CO)	USEPA 10: 1996/By Flue Gas Analyzer	3.42	PPM	0.1	
5	Carbon Dioxide as CO ₂	USEPA 3A:1989	9.6	%	0.1	
6	Oxygen as O ₂	USEPA 3A:1989	7.3	%	0.1	
7	Mercury as (Hg)	USEPA 29:1996/101A:1991	BLQ(LOQ: 0.001)	mg/Nm ³	0.001	

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

Remark-1: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By 


Parmeshwar Lal
Authorised Signatory

TEST REPORT

Report No.		ISSPL/EN/24-25/20198/B	Date	20/12/2024
1.	Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2.	Reference No.	Your TRF Dated: 15/12/2024 (Reg. No. 78802)		
3.	Material Identification with details	Boiler Stack: Date and Time of Sampling: 14/12/2024 (11:40 pm to 12:10 pm), Qty. 1 No.		
4.	Sample code	78802		
5.	Date of sampling	14/12/2024		
6.	Date of Sample testing	15/12/2024 To 20/12/2024		
7.	Sampling duration (in minutes)	30 Min.		
8.	Sampling Location	Boiler Stack (Unit-1 Third Unit) 660 MW		
9.	Sampling Protocol	IS:11255 (Pt-1) 1985 (RA 2014)		
10.	Type of stack	MS Circular		
11.	Stack attached to	Boiler Stack		
12.	Stack Diameter (in meters)	7.2		
13.	Stack height (in meters)	275		
14.	Type and quantity of fuel used	Coal		
15.	Instrument Code & Calibration Status	ISSPL/INS/C/134		
16.	Control Measures if any	-		
17.	Ambient Temperature (oC)	26°C		
18.	Flue Gas Temperature (oC)	133°C		

RESULTS

S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
3I. Chemical Testing:-					
1. Atmospheric Pollution:-					
1	Velocity of Gas	CPCB Emission	25.8	m/s	Not Specified

Page No. 1/2

Reviewed By


 Parneshwar Lal
 Authorised Signatory



SYSTEMS AND SOLUTIONS PRIVATE LIMITED

(Promoted by Indian Register of Shipping)

Testing Laboratory

CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,

Malviya Nagar, Jaipur, Rajasthan – 302017: India

Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20198/B		Date	20/12/2024
S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
		Regulation(Part -3)			
2	Temperature	CPCB Emission Regulation(Part -3)	142	°C	5
3	Moisture	USEPA 4	11.5	%	1

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

Remark-1: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Page No. 2/2

Reviewed By 





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20199/A		Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab			
2. Reference No.	Your TRF Dated: 15/12/2024 (Reg. No. 78801)			
3. Material Identification with details	Boiler Stack: Date and Time of Sampling: 14/12/2024 (11:00 am to 11:30 am), Qty. 1 No.			
4. Sample code	78801			
5. Date of sampling	14/12/2024			
6. Date of Sample testing	15/12/2024 To 20/12/2024			
7. Sampling duration (in minutes)	30 Min.			
8. Sampling Location	Boiler Stack (Unit-2 First Unit) 660 MW			
9. Sampling Protocol	IS:11255 (Pt-1) 1985 (RA 2014)			
10. Type of stack	MS Circular			
11. Stack attached to	Boiler Stack			
12. Stack Diameter (in meters)	7.2			
13. Stack height (in meters)	275			
14. Type and quantity of fuel used	Coal			
15. Instrument Code & Calibration Status	ISSPL/INS/C/134			
16. Control Measures if any	-			
17. Ambient Temperature (oC)	26°C			
18. Flue Gas Temperature (oC)	131°C			

RESULTS

S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
3. Chemical Testing:-					
1. Atmospheric Pollution:-					
1	Particulate Matter (PM) at 6% O2 Corr.	IS 11255 (Part 1) 1985, RA:	37	mg/Nm3	1

Page No. 1/2

Reviewed By


 Parmeshwar Lal
 Authorized Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,

Malviya Nagar, Jaipur, Rajasthan – 302017: India

Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20199/A			Date	20/12/2024
S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
		2019			
2	Sulphur dioxide (SO ₂) at 6% O ₂ Corr.	USEPA 6C: 1996/By Flue Gas Analyzer	904	mg/Nm ³	0.3
3	Oxides of Nitrogen (NO _X) at 6% O ₂ Corr.	USEPA 7E: 1990/By Flue Gas Analyzer	211.14	mg/Nm ³	0.2
4	Carbon Monoxide as (CO)	USEPA 10: 1996/By Flue Gas Analyzer	4.4	PPM	0.1
5	Carbon Dioxide as CO ₂	USEPA 3A:1989	9.2	%	0.1
6	Oxygen as O ₂	USEPA 3A:1989	8.3	%	0.1
7	Mercury as (Hg)	USEPA 29:1996/101A:1991	BLQ(LOQ: 0.001)	mg/Nm ³	0.001

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

Remark-1: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By



TEST REPORT

Report No.	ISSPL/EN/24-25/20199/B	Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2. Reference No.	Your TRF Dated: 15/12/2024 (Reg. No. 78801)		
3. Material Identification with details	Boiler Stack: Date and Time of Sampling: 14/12/2024 (11:00 am to 11:30 am), Qty. 1 No.		
4. Sample code	78801		
5. Date of sampling	14/12/2024		
6. Date of Sample testing	15/12/2024 To 20/12/2024		
7. Sampling duration (in minutes)	30 Min.		
8. Sampling Location	Boiler Stack (Unit-2 First Unit) 660 MW		
9. Sampling Protocol	IS:11255 (Pt-1) 1985 (RA 2014)		
10. Type of stack	MS Circular		
11. Stack attached to	Boiler Stack		
12. Stack Diameter (in meters)	7.2		
13. Stack height (in meters)	275		
14. Type and quantity of fuel used	Coal		
15. Instrument Code & Calibration Status	ISSPL/INS/C/134		
16. Control Measures if any	-		
17. Ambient Temperature (oC)	26°C		
18. Flue Gas Temperature (oC)	131°C		

RESULTS

S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
3I. Chemical Testing:-					
1. Atmospheric Pollution:-					
1	Velocity of Gas	CPCB Emission	25.6	m/s	Not Specified

Page No. 1/2

Reviewed By





SYSTEMS AND SOLUTIONS PRIVATE LIMITED

(Promoted by Indian Register of Shipping)

Testing Laboratory

CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,

Malviya Nagar, Jaipur, Rajasthan – 302017: India

Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20199/B		Date	20/12/2024
S.No.	Test Parameters	Test Method	Results	Units	Detection Limit
		Regulation(Part -3)			
2	Temperature	CPCB Emission Regulation(Part -3)	124	°C	5
3	Moisture	USEPA 4	11.6	%	1

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

Remark-1: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Page No. 2/2

Reviewed By





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20209	Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2. Reference No.	Your TRF 16/12/2024 (Reg. No. 78791)		
3. Material Identification with details	Ambient Air Quality Monitoring: Qty. 1 No.		
4. Date of Sampling	13/12/2024 to 14/12/2024		
5. Time of Sampling	11:00 am to 11:00 am		
6. Sampling Location	Station No. 01 (CAAQMS)		
7. Sampling Protocol	IS:5182 (Pt-14) 2000		
8. Duration of Sampling (Minutes)	1440 Min.		
9. Test Started On	16/12/2024		
10. Test Completed On	20/12/2024		
11. Date of sample Testing	16/12/2024 To 20/12/2024		
12. Nature & Activity of the Unit	Human and Plant Site Activities		
13. Ambient Temperature (oC)	Min. 12°C, Max. 22°C		
14. Weather Condition during Monitoring	Clear Sky		
15. Instrument Code & Calibration Status	ISSPL/INS/C/212, ISSPL/INS/197, ISSPL/INS/C/126		

RESULTS

S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
I. Chemical Parameter:-						
1. Atmospheric Pollution						
1	Sulphur Dioxide (as SO ₂)	IS:5182 (Part 2)-2001, Reaff :2017	8.1	µg/m ³	80 (Max.)	4
2	Nitrogen Dioxide(as NO ₂)	IS:5182 (Part 6)-2006, Reaff	30.8	µg/m ³	80 (Max.)	6

Page No. 1/2

8
Reviewed By


 Authorised Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20209			Date		20/12/2024
S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit	
2		:2017					
3	Particulate Matter (as PM2.5)	IS:5182 (Part 24):2019	29.76	µg/m ³	60 (Max.)	1	
4	Particulate Matter (as PM10)	IS:5182 (Part 23)-2006, Reaff:2017	68.14	µg/m ³	100 (Max.)	1	
5	Carbon Monoxide (as CO)	IS 5182 (Part -10):1999	1.24	mg/m ³	4 (Max.)	0.02	
6	Lead (as Pb)	USEPA Method IO 3.5 1999	BLQ(LOQ:0.0005)	µg/m ³	1.0 (Max.)	0.0005	

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

*NAAQS- National Ambient Air Quality Standards; Schedule-VII, [Rule 3 (3B)], [Part-II-se.-3(i)] 16.11.2009.

Remark: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20193	Date	20/12/2024
1.	Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2.	Reference No.	Your TRF 15/12/2024 (Reg. No. 78807)		
3.	Material Identification with details	Ambient Air Quality Monitoring: Qty. 1 No.		
4.	Date of Sampling	13/12/2024 to 14/12/2024		
5.	Time of Sampling	10:30 am to 10:30 am		
6.	Sampling Location	Station No. 02 (CAAQMS)		
7.	Sampling Protocol	IS:5182 (Pt-14) 2000		
8.	Duration of Sampling (Minutes)	1440 Min.		
9.	Test Started On	15/12/2024		
10.	Test Completed On	20/12/2024		
11.	Date of sample Testing	15/12/2024 To 20/12/2024		
12.	Nature & Activity of the Unit	Human and Plant Site Activities		
13.	Ambient Temperature (oC)	Min. 12°C, Max. 22°C		
14.	Weather Condition during Monitoring	Clear Sky		
15.	Instrument Code & Calibration Status	ISSPL/INS/C/172, ISSPL/INS/209, ISSPL/INS/C/123		

RESULTS

S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
I. Chemical Parameter:-						
1. Atmospheric Pollution						
1	Sulphur Dioxide (as SO ₂)	IS:5182 (Part 2)-2001, Reaff :2017	8.5	µg/m ³	80 (Max.)	4
2	Nitrogen Dioxide(as NO ₂)	IS:5182 (Part 6)-2006, Reaff	31.6	µg/m ³	80 (Max.)	6

Page No. 1/2

Reviewed By





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20193			Date		20/12/2024
S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit	
2		:2017					
3	Particulate Matter (as PM2.5)	IS:5182 (Part 24):2019	37.63	µg/m ³	60 (Max.)	1	
4	Particulate Matter (as PM10)	IS:5182 (Part 23)-2006, Reaff:2017	73.21	µg/m ³	100 (Max.)	1	
5	Carbon Monoxide (as CO)	IS 5182 (Part -10):1999	1.61	mg/m ³	4 (Max.)	0.02	
6	Lead (as Pb)	USEPA Method IO 3.5 1999	BLQ(LOQ:0.0005)	µg/m ³	1.0 (Max.)	0.0005	

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

*NAAQS- National Ambient Air Quality Standards; Schedule-VII, [Rule 3 (3B)], [Part-II-se.-3(i)] 16.11.2009.

Remark: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By

Jaipur
Parmeshwar Lal
Authorised Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20210		Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab			
2. Reference No.	Your TRF 16/12/2024 (Reg. No. 78790)			
3. Material Identification with details	Ambient Air Quality Monitoring: Qty. 1 No.			
4. Date of Sampling	13/12/2024 to 14/12/2024			
5. Time of Sampling	11:30 am to 11:30 am			
6. Sampling Location	Station No 3 (CAAQMS)			
7. Sampling Protocol	IS:5182 (Pt-14) 2000			
8. Duration of Sampling (Minutes)	1440 Min.			
9. Test Started On	16/12/2024			
10. Test Completed On	20/12/2024			
11. Date of sample Testing	16/12/2024 To 20/12/2024			
12. Nature & Activity of the Unit	Human and Plant Site Activities			
13. Ambient Temperature (oC)	Min. 12°C, Max. 22°C			
14. Weather Condition during Monitoring	Clear Sky			
15. Instrument Code & Calibration Status	ISSPL/INS/C/214, ISSPL/INS/228, ISSPL/INS/C/219			

RESULTS

S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
I. Chemical Parameter:-						
1. Atmospheric Pollution						
1	Sulphur Dioxide (as SO ₂)	IS:5182 (Part 2)-2001, Reaff :2017	9.4	µg/m ³	80 (Max.)	4
2	Nitrogen Dioxide(as NO ₂)	IS:5182 (Part 6)-2006, Reaff	34.7	µg/m ³	80 (Max.)	6

Page No. 1/2

Reviewed By



 Parmeshwar Lal
 Authorised Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,

Malviya Nagar, Jaipur, Rajasthan – 302017: India

Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20210				Date	20/12/2024
S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
2		:2017				
3	Particulate Matter (as PM2.5)	IS:5182 (Part 24):2019	38.95	µg/m ³	60 (Max.)	1
4	Particulate Matter (as PM10)	IS:5182 (Part 23)-2006, Reaff:2017	84.97	µg/m ³	100 (Max.)	1
5	Carbon Monoxide (as CO)	IS 5182 (Part -10):1999	1.38	mg/m ³	4 (Max.)	0.02
6	Lead (as Pb)	USEPA Method IO 3.5 1999	BLQ(LOQ:0.0005)	µg/m ³	1.0 (Max.)	0.0005

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

*NAAQS- National Ambient Air Quality Standards; Schedule-VII, [Rule 3 (3B)], [Part-II-se.-3(i)] 16.11.2009.

Remark: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

End of the Report

Reviewed By
8

IRCLASS Systems And Solutions
Jaipur
Parmeshwar Lal
Authorised Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20194		Date	20/12/2024
1.	Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2.	Reference No.	Your TRF 15/12/2024 (Reg. No. 78806)		
3.	Material Identification with details	Ambient Air Quality Monitoring: Qty. 1 No.		
4.	Date of Sampling	13/12/2024 to 14/12/2024		
5.	Time of Sampling	11:00 am to 11:00 am		
6.	Sampling Location	Station No. 04 (CAAQMS)		
7.	Sampling Protocol	IS:5182 (Pt-14) 2000		
8.	Duration of Sampling (Minutes)	1440 Min.		
9.	Test Started On	15/12/2024		
10.	Test Completed On	20/12/2024		
11.	Date of sample Testing	15/12/2024 To 20/12/2024		
12.	Nature & Activity of the Unit	Human and Plant Site Activities		
13.	Ambient Temperature (oC)	Min. 12°C, Max. 22°C		
14.	Weather Condition during Monitoring	Clear Sky		
15.	Instrument Code & Calibration Status	ISSPL/INS/C/172, ISSPL/INS/209, ISSPL/INS/C/123		

RESULTS

S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
I. Chemical Parameter:-						
1. Atmospheric Pollution						
1	Sulphur Dioxide (as SO ₂)	IS:5182 (Part 2)-2001, Reaff :2017	8.8	µg/m ³	80 (Max.)	4
2	Nitrogen Dioxide(as NO ₂)	IS:5182 (Part 6)-2006, Reaff	32.5	µg/m ³	80 (Max.)	6

Page No. 1/2

Reviewed By


 Jaipur
 Parmeshwar Lal
 Authorized Signatory



CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20194			Date	
S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
2		:2017				
3	Particulate Matter (as PM2.5)	IS:5182 (Part 24):2019	32.18	µg/m ³	60 (Max.)	1
4	Particulate Matter (as PM10)	IS:5182 (Part 23)-2006, Reaff:2017	76.92	µg/m ³	100 (Max.)	1
5	Carbon Monoxide (as CO)	IS 5182 (Part -10):1999	1.41	mg/m ³	4 (Max.)	0.02
6	Lead (as Pb)	USEPA Method IO 3.5 1999	BLQ(LOQ:0.0005)	µg/m ³	1.0 (Max.)	0.0005

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

*NAAQS- National Ambient Air Quality Standards; Schedule-VII, [Rule 3 (3B)], [Part-II-se.-3(i)] 16.11.2009.

Remark: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By





CEG Tower, 1st & 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.	ISSPL/EN/24-25/20195	Date	20/12/2024
1. Name & address of Customer	Power Mech Project Limited Talwandi Sabo Power Ltd., 3X660MW Thermal Power Plant, Banawala, Mansa District Punjab		
2. Reference No.	Your TRF 15/12/2024 (Reg. No. 78805)		
3. Material Identification with details	Ambient Air Quality Monitoring: Qty. 1 No.		
4. Date of Sampling	14/12/2024 to 15/12/2024		
5. Time of Sampling	11:30 am to 11:30 am		
6. Sampling Location	Village Chelanwali		
7. Sampling Protocol	IS:5182 (Pt-14) 2000		
8. Duration of Sampling (Minutes)	1440 Min.		
9. Test Started On	15/12/2024		
10. Test Completed On	20/12/2024		
11. Date of sample Testing	15/12/2024 To 20/12/2024		
12. Nature & Activity of the Unit	Human and Plant Site Activities		
13. Ambient Temperature (oC)	Min. 12°C, Max. 22°C		
14. Weather Condition during Monitoring	Clear Sky		
15. Instrument Code & Calibration Status	ISSPL/INS/C/172, ISSPL/INS/209, ISSPL/INS/C/123		

RESULTS

S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
I. Chemical Parameter:-						
1. Atmospheric Pollution						
1	Sulphur Dioxide (as SO ₂)	IS:5182 (Part 2)-2001, Reaff :2017	9.9	µg/m ³	80 (Max.)	4
2	Nitrogen Dioxide(as NO ₂)	IS:5182 (Part 6)-2006, Reaff	33.1	µg/m ³	80 (Max.)	6

Page No. 1/2

Reviewed By 





CEG Tower, 1st& 2nd Floor, B-11G, Industrial Area,
Malviya Nagar, Jaipur, Rajasthan – 302017: India
Tel: 0141-4805672 | Email – lab@irclass.org | Website : www.isspllab.com

TEST REPORT

Report No.		ISSPL/EN/24-25/20195			Date	
S.No.	Name of Test	Method of Test	Results	Unit	Limit as per NAAQS*	Detection Limit
2		:2017				
3	Particulate Matter (as PM2.5)	IS:5182 (Part 24):2019	36.14	µg/m ³	60 (Max.)	1
4	Particulate Matter (as PM10)	IS:5182 (Part 23)-2006, Reaff:2017	86.79	µg/m ³	100 (Max.)	1
5	Carbon Monoxide (as CO)	IS 5182 (Part -10):1999	1.52	mg/m ³	4 (Max.)	0.02
6	Lead (as Pb)	USEPA Method IO 3.5 1999	BLQ(LOQ:0.0005)	µg/m ³	1.0 (Max.)	0.0005

BLQ= Below Limit of Quantification, LOQ= Limit of Quantification

*NAAQS- National Ambient Air Quality Standards; Schedule-VII, [Rule 3 (3B)], [Part-II-se.-3(i)] 16.11.2009.

Remark: Sampling done by ISSPL Representative (Mr.Pokhar Nath Yogi).

****End of the Report****

Reviewed By

